

VILLAGE OF TUXEDO PARK
P.O. BOX 31
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
October 25, 2021 to November 16, 2021

Roads

1. Transferred mailboxes on to new mailbox holder on Continental Road
2. Removed fallen trees on West Lake Road, Ontio Road
3. Cleaned drains and catch basins ahead of rains and after rains
4. Removed large dangerous pine tree at the South Gate
5. Leveled and permanently installed bollards at the Front Gate and asphalt patched around Police Booth
6. Removed brush at the Village Office near Cheung property
7. Patched East Lake Road at areas of valve replacements
8. Patched Stable Road at area of water leak repair
9. Installed bullet proof window at the Police Booth
10. Cleaned leaves from the Village office
11. Reclaimed (ground up) Turtle Point Road, part of West Lake Road and the top of Summit Road; will be paving on 11/17/21 and 11/18/21
12. Worked on building more mailbox stands
13. Patched around triangle on West Lake Road and Brook Road

Water

1. Removed seasonal water meters
2. Located water valve boxes and manholes on roads that were ground up
3. Took weekly meter readings at Village-owned buildings
4. Removed meter, turned water off, and winterized the bathrooms at Wee Wah Park
5. Turned water off and removed meter at the end of old Orange Top Inn
6. Prepared and sent monthly water report to the Health Department
7. Filled chemical crocks as needed
8. Turned off water at 10 East Place for water line repair
9. Greased pumps and equipment at the Water Plant
10. Turned on heat in all buildings
11. Performed sampling at the Water Plant

Sewer

1. Had sludge removed from Sewer Plant
2. Checked Turtle Point Road pump station regularly
3. Greased pumps and equipment at the Sewer Plant
4. Had flow meter repaired at the Sewer Plant (bad ground wire)

5. Did daily maintenance and sampling at the Sewer Plant
6. Installed tarp over digesters at the Sewer Plant for the winter
7. Did various water and sewer line markouts