INCORPORATED 1952 (845) 351-4745 (Voice) (845) 351-2668 (Fax) Website: tuxedopark-ny.gov

VILLAGE OF TUXEDO PARK

80 LORILLARD ROAD TUXEDO PARK, NEW YORK 10987

DPW Report August 20, 2024 to September 17, 2024

DPW

- 1. Patched potholes on Ridge Road, East Lake Road, Cliff Road, West Lake Road, Acoma Road, Turtle Point Road, Terrace Road and at South Gate
- 2. Installed asphalt gutters on Turtle Point Road as part of a drainage issue solution
- 3. Weed-whacked East Lake Road, Camp Comfort Road, Wee Wah Road, Upper Continental Road, Mountain Farm Road, Triangle on Ridge Road, West lake Stable Road, Wee Wah Dam, Lorillard Road, Cannon Hill Road
- 4. Cut grass throughout Village
- 5. Blacktopped storm gutter on upper Continental Road
- 6. Cut back brush on Potucket Road
- 7. Removed fallen trees on access road to the Potucket tanks, West Lake Road
- 8. Removed swimming boundary ropes and buoys at Wee Wah Park; stored in shed
- 9. Brought in the raft at Wee Wah Park and secured to dock
- 10. Worked on asphalt paving machine

Water and Sewer

- 1. Did various utility markouts for Dig Safe NY
- 2. Worked on removing aluminum screens from water filter at the Water Plant after screens failed
- 3. Removed plastic filter media from a decant tank at the Water Plant caused by screen failure
- 4. Ordered new filter screens for both filters at the Water Plant
- 5. Obtained various meter readings requested by Denise Spalthoff
- 6. Started third quarter meter readings
- 7. Dismantled old water meters and took them to the scrap yard; received a check for \$712.50
- 8. Repaired one water meter
- 9. Met with electrician at the Mountain Farm Pump Station for an electrical issue
- 10. Continued weekend and holiday Water and Sewer operations
- 11. Obtained meter readings on Village accounts
- 12. Obtained water pressure readings at the Villa Apartments and at the DeBordenave residence on Crows Nest Road
- 13. Cleared sewer blockage on Turtle Mountain Road
- 14. Flushed a fire hydrant on Camp Comfort Road after complaint of discolored water
- 15. Changed oil and filter on air compressor at the Water Plant
- 16. Replaced 2" ball valves and plastic sludge line piping at the Sewer Plant