

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
November 19, 2025 to December 16, 2025

DPW

1. Picked up leaves throughout the Village
2. Worked on plows and salt spreaders
3. Opened main valve and removed three stop logs at the Wee Wah Dam to drop lake level for winter
4. Worked on trucks and equipment
5. Removed leaf box from flat bed truck and mounted salt spreader ahead of snow
6. Plowed roads on 12/2, 12/13 and 12/14
7. Salted roads on 12/2, 12/3, 12/10, 12/13 and 12/14
8. Washed and cleaned all trucks and salt spreaders after snow events
9. Cleared snow away from rental garages at Village Hall
10. Installed Christmas lights at the main gate and tree on St. Mary's property
11. Cleaned drains and catch basins
12. Picked up truck from Arkel Motors and mounted salt spreader
13. Repaired gate arm at the Front Gate
14. Received and stored all salt deliveries

Water and Sewer

1. Removed wall mount propane heater in the chlorine building at the Sewer Plant and installed new ceiling mount electric heater
2. Cleared sewer blockage at 15 Ridge Road
3. Removed seasonal and irrigation meters
4. Began fourth quarter meter reading
5. Repaired leak on 1¼ water line on Clubhouse Road
6. Worked on filter at the water plant
7. Worked on raw water check valves at Water Plant
8. Shut off water to 93 Nursery Road after frozen and broken pipes due to no heat
9. Located shut-off valve to 20 East Place
10. Performed utility mark-outs for Dig Safe NY
11. Checked heat in all buildings
12. Obtained water samples after boil water due to water line repair on Clubhouse Road