

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
December 17, 2024 to January 13, 2024

DPW

1. Worked on Christmas lights at the front gate
2. Worked on plow equipment, salt spreaders
3. Replaced transmission pan and filter on 2014-350 dump truck
4. Worked with Nelson Tree Service removing dead trees on Turtle Point Road and Fox Hill Road
5. Salted Roads on December 20, 21, 28 and January 6 and 11
6. Plowed roads on December 21 and December 24
7. Received and put away salt shipments into storage shed
8. Replaced transmission pan on water truck
9. Replaced leaking hydraulic hose on cat loader
10. Washed trucks after plowing and salting
11. Picked up Christmas trees
12. Picked up fallen trees on West Lake Road, Summit Road, East Lake Stable Road
13. Picked up sticks and branches after high winds
14. Replaced tie rod ends and did oil change on 2014 F-250 pickup, also replaced battery
15. Cut access holes in foundation at Chastellux to repair broken heat pipes under the house
16. Cut down dangerous tree on Summit Road
17. Covered up access holes at Chastellux

Water and Sewer

1. Repaired water main break at SOS Fuels
2. Repaired leaking 2" water main on East Village Road
3. Repaired leaking water service line at the chlorine building at the Sewer Plant
4. Thawed out frozen pipes at the Sewer Plant
5. Read water meters
6. Continued weekend and holiday water and sewer operations
7. Cleared sewer blockage at 2 Stable Road
8. Checked heat in all buildings
9. Did various utility mark-outs for Dig Safe NY
10. Replaced faulty valve in hot water heater at the Chastellux Rental