INCORPORATED 1952 (845) 351-4745 (Voice) (845) 351-2668 (Fax) Website: tuxedopark-ny.gov

VILLAGE OF TUXEDO PARK

80 LORILLARD ROAD TUXEDO PARK, NEW YORK 10987

DPW Report January 14, 2025 to February 27, 2025

DPW

- 1. Plowed and salted roads on January 16, 19 and 20; and on February 2, 3, 8, 9, 15, 16 and 20
- 2. Patched potholes
- 3. Washed trucks and salt spreaders between storms
- 4. Worked on plow equipment and salt spreaders
- 5. Received and stored salt deliveries
- 6. Cleared snow from ice at Wee Wah Park for ice skating
- 7. Removed fallen trees on West Lake Road, Lookout Road
- 8. Cut down dangerous trees at the DPW and Front Gate
- 9. Cleared snow away from catch basins
- 10. Worked on trucks and heavy equipment
- 11. Picked up Christmas trees
- 12. Cleaned up around the DPW
- 13. Added stone to water leak excavations on East Village Road and Mountain Road
- 14. Picked up leaves on East Lake Road, Circuit Road and Sewer Plant
- 15. Cut brush on Tuxedo Road causeway, Clubhouse Road, East Lake Stable Road, Laurel Road, Circuit Road
- 16. Picked up donated generator and transported to the Police Department
- 17. Picked up sticks and branches after heavy winds

Water and Sewer

- 1. Repaired a 1 1/4" water line near Steve's Pizza
- 2. Repaired a 4" water main on Park Avenue
- 3. Obtained water samples due to boil water after water main repairs, and transported to lab
- 4. Worked on lead line survey per DOH
- 5. Finished reading water meters
- 6. Obtained various meter readings requested by Denise Spalthoff
- 7. Repaired 6" water main on Mountain Road
- 8. Had both pressure regulators in the Town rebuilt by Ross Valve Co.
- 9. Did various utility mark-outs for Dig Safe NY
- 10. Investigated running water in the gutter below the Booth residence on Tuxedo Road; found broken pipes inside house; turned water off in basement
- 11. Checked heat in all buildings and pump houses
- 12. Continued weekend and holiday water/sewer operations
- 13. Flushed water main on Wee Wah Road
- 14. Replaced two water meters