

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
February 15, 2022 to March 14, 2022

Roads

1. Installed signs at the Police Station, Water Plant and Sewer Plant
2. Plowed and/or salted roads on 2/25, 3/9 and 3/12
3. Salted roads on 2/19, 2/25, 3/9, 3/12, and 3/13
4. Received 125.91 tons of salt
5. Shoveled off snow at the Wee Wah Park for ice skating
6. Repaired water main break on Schoolhouse Road
7. Cleaned up trees and branches after storm on 3/9
8. Cut down large dead tree trunk on Ridge Road
9. Washed and cleaned trucks and salt spreaders after storms
10. Worked on trucks and plows
11. Loaded Perkins motor and old Kohler generator for people that purchased them off of Auction Surplus

Water

1. Fixed meter touchpads
2. Installed new meter and touchpad at Stalnakers – Contractor’s Road
3. Filled chemical crocks as needed
4. Greased pumps and equipment
5. Checked heaters in all buildings
6. Took weekly and various meter readings
7. Repaired water main break on Schoolhouse Road
8. Repaired broken gate box cap by the Tuxedo Club
9. Prepared and sent monthly water report to the Health Department
10. Started 1st quarter meter readings
11. Turned service line off at 113 East Village Road for plumbing repairs; found shutoff in concrete floor of neighbor’s property
12. Performed bi-monthly compliance testing

Sewer

1. Performed daily maintenance at Plant
2. Installed new exterior door on the digester building
3. Cleared sewer blockage at 35 West Lake Stable Road
4. Greased pumps and equipment at Plant
5. Checked Turtle Point Road Pump Station regularly
6. Prepared and sent monthly sewer report to the DEC
7. Installed a new chlorine pump
8. Did daily and bi-monthly sampling