

VILLAGE OF TUXEDO PARK
80 LORILLARD ROAD
TUXEDO PARK, NEW YORK 10987

DPW Report
September 18, 2024 to October 21, 2024

DPW

1. Patched potholes on Terrace Road
2. Blacktopped gutter on Cliff Road
3. Worked on International Dump Truck
4. Cut grass throughout the Village
5. Removed invasive vines on the Tuxedo Road causeway and trimmed bushes
6. Cut invasive vines on West Lake Road and Eagle Mountain Road
7. Weed-whacked Pine Road, Tuxedo Road, Ontio Road, Potuckit Water Tank, Lookout Mountain Road
8. Steam-cleaned boat trailers
9. Repaired storm drain head wall on Ontio Road
10. Installed new 12 inch drain pipes on Pine Hill Road, Laurel Road and Ridge Road
11. Installed two catch basins on Laurel Road
12. Weed-whacked the Pond 3 Dam embankment
13. Trimmed tall grasses on triangle at the intersection of Tuxedo Road and Ontio Road
14. Cut grass and blew leaves at Wee Wah Park
15. Worked on getting leaf machine ready
16. Cleaned up large tree on East Lake Stable Road cut down by Orange & Rockland
17. Worked with Sterling Carting on bulk pick-up
18. Picked up leaves with leaf machine
19. Blew leaves off of the triangle on Ridge Road and triangle by Tuxedo Club
20. Installed a new sign post at the top of Pepperidge Road

Water and Sewer

1. Finished 3rd quarter water meter readings
2. Replaced an 8 inch water main valve on Clubhouse Road
3. Repaired a 1 inch water line leak on Patterson Hill Road
4. Repaired a 4 inch water main line break on Schoolhouse Lane
5. Obtained and transported water samples to the lab due to water main breaks
6. Responded to the Mengel residence due to low water pressure complaint; filter was clogged
7. Obtained water pressure readings on Crows Nest Road
8. Continued weekend and holiday water and sewer operations
9. Worked on service line inventory requested by DOH
10. Repaired a water meter in the East Village
11. Responded to the Hargroves residence on Clubhouse Road due to complaint of low water pressure; removed filter and flushed water service line
12. Removed faulty electric motor at the sewer plant; ordered new motor
13. Installed a new battery backup at the Sewer Plant
14. Met with homeowner at 86 Potuckit Road to investigate water meter issue
15. Marked out water main on Route 17
16. Installed new GFI outlets at the Sewer Plant

17. Emptied clarifier tank at the Sewer Plant after plastic chain on the chain and flight system snapped; ordered new parts
18. Changed all grease fittings on drive sprockets in clarifier at the Sewer Plant
19. Worked on propane heater in the chlorine building at the Sewer Plant