

Village of Tuxedo Park
 Water Loss Analysis 2000-2016

11/14/2018

Year	Water Processed	Water Billed	Water Loss	Percent Loss
2016	129,522,000	52,845,550	76,676,450	59%
2015	135,753,000	57,796,460	77,956,540	57%
2014	108,887,000	55,325,550	53,561,450	49%
2013	126,354,000	56,542,718	69,811,282	55%
2012	142,654,300	66,882,410	75,771,890	53%
2011	116,491,000	62,309,839	54,181,161	47%
2010	120,225,000	65,165,770	55,059,230	46%
2009	108,075,000	49,290,080	58,784,920	54%
2008	103,216,000	55,570,240	47,645,760	46%
2007	124,861,000	75,226,040	49,634,960	40%
2006	106,038,000	52,823,485	53,214,515	50%
2005	140,928,000	57,570,650	83,357,350	59%
2004	143,248,000	59,791,580	83,456,420	58%
2003	111,072,000	56,096,645	52,962,715	48%
2002	99,253,000	59,279,519	39,973,481	40%
2001	107,090,000	58,875,297	48,214,703	45%
2000	127,406,000	64,400,334	63,005,666	49%
			Average	50%

Annual Water Plant Report

11/15/2018

2017	Town	Village	Seasonal	Municipal	Total Gallons		Total Processed Water	Gallons Lost	Loss %
					Billed + Municipal	Water			
Q1	0	0	0	0	0	0	0	0	0%
Q2	4,667,295	5,862,368	0	0	10,529,663	27,690,000	17,160,337	62%	
Q3	4,066,783	10,663,413	2,070,978	0	16,801,174	31,629,000	14,827,827	47%	
Q4	6,176,130	6,710,338	0	1,493,920	14,380,388	33,259,000	18,878,612	57%	
Total	14,910,208	23,236,119	2,070,978	1,493,920	41,711,225	92,578,000	50,866,776	55%	

2018	Town	Village	Seasonal	Municipal	Total Gallons		Total Processed Water	Gallons Lost	Loss %
					Billed + Municipal	Water			
Q1	4,841,422	3,997,504	0	3,476,216	12,315,142	32,930,000	20,614,858	63%	
Q2	6,110,260	5,468,615	0	4,486,948	16,065,823	37,917,000	21,851,177	58%	
Q3	5,509,660	11,094,810	1,685,000	0	18,289,470	38,608,000	20,318,530	53%	
Q4	0	0	0	0	0	0	0	0%	
Total	16,461,342	20,560,929	1,685,000	7,963,164	46,670,435	109,455,000	62,784,565	57%	